



GOVERNMENT OF ARUNACHAL PRADESH
OFFICE OF THE ASSISTANT ENGINEER::::: PHE & WS DEPARTMENT
SUB-DIVISION:::::::::: PASIGHAT

No.AEP/PHE/E-34/2020-21/89

Dated Pasighat the 10th June'2024

"TO WHOM IT MAY CONCERN"

This is to certify that an inspected team headed by Junior Engineer from PHE & WS Sub-Division, Pasighat, inspected Daying Ering Memoriel Govt. Higher Secondary School Pasighat on 4th June'2024 and found that Daying Ering Memorial Govt. Highger Secondary School Pasighat, has safe drinking water facilities for the students and members of staff within the campus and is maintaining the hygienic sanitation condition in the school building and the campus as pert the norms prescribed by the Government of Arunachal Pradesh.

This is valid for a period of Three (3) years.

To,

The Pricipal/Headmaster

DEM G.H.S School.....*Pasighat*

East Siang District

Arunachal Pradesh


Signature with seal.....

Name: Er. Eleena *Assistant Engineer*

Designation: *PHE & WS Sub-Division*
Assistant Engineer

Pasighat (A.P)


10/6/24



WATER QUALITY TEST REPORT OF D.Ering M G Hr.S.School

Sl.No	Name of Source	Date of collection/water sample test	Turbidity	pH value	Total Hardness mg/L	Total Iron mg/L	Chloride mg/L	Nitrate mg/L	Flouride mg/L	Sulphate mg/L	Alkanity (M)	Manganese	TDS	Bactriological Test
1	Bore well	10-06-24	0.47 NTU	6.85	40.0mg/l	0.10mg/l	4.3mg/l	0.62mg/l	0.00 mg/L	2 mg/L	25 mg/L	0.18 mg/L	62.3ppm	Neg-ve
Acceptable Range:-			5.0	6.5 - 8.5	200	0.3	200.00	45.00	1.0 - 1.5	200	200	0.1 - 0.3	500	Neg-ve


Lab Assistant
PHE & WS Sub-Division,
Pasighat


Assistant Engineer
PHE & WS Sub-Division,
Pasighat
10/6/24